



We help ideas meet the real world



Compliance Statement

No. 2010-101

Screened Permanent Link, Class E_A for 10GBASE-T

Company

Pouyet SA
3M Telecommunications
Boulevard de l'Oise
95006 Cergy Pontoise Cedex
France

Permanent Link Identification (3 connector model)

Horizontal cable:

VOL-6AFL4 Volition™ Cat.6A F/UTP cable, 4 pairs, LS0H
VOL-6AFL8 Volition™ Cat.6A F/UTP cable, 2x4 pairs, LS0H

Flexible Cords:

VOL-10SFL-Lx Volition™ 10 gigabits S/FTP cords, 4 pairs, LS0H

RJ45 screened Jack for Wall Outlet, Consolidation Point, and Patch Panel:

OCK-6A Volition™ RJ45 Jack, Cat.6A shielded

Generic cabling standards, cabling components standard

- ISO/IEC 11801 2nd edition:2002
- ISO/IEC 11801 amendment 2:2010, Class E_A
- ANSI/TIA-568-C.2, Category 6A
- EN 50173:2007

Technical report

DELTA-N312772-02, DANAK-19J2249

Manufacturer code

2249A

Certificate valid until

20 June 2011

This product has been tested by DELTA EC Cabling Group and complies with the electrical requirements of the above specified standards. Furthermore, it complies with "Terms and conditions for use of the EC VERIFIED marking on generic cabling products", DQP231006. The product takes part in a maintenance of certification schedule, which implies that DELTA EC Cabling performs a sample test of the product once a year.

Hørsholm 20 May 2010

Erik Bech
Test Manager

Claude Videt
Project Manager

DELTA

Venlighedsvej 4
2970 Hørsholm
Denmark

Tel. +45 72 19 40 00
Fax +45 72 19 40 01
www.delta.dk/cable



TEST Reg. no. 19