We help ideas meet the real world

Compliance Statement

No. 2010-148

Connecting Hardware, Category 6

Company
ELKO AS
Eyvind Lyches vei 10
1338 Sandvika
Norway

Product description
Unscreened Category 6 RJ45 jack characterised up to 250 MHz, 100 Ω

Product identification
Telesafe Compact Connector RJ45 P/N 2590 Category 6, unscreened

Generic cabling standards, cabling components standard

- ISO/IEC 11801 2nd edition:2002
- ISO/IEC 11801 amendment 2:2010
- EN 50173:2007
- ANSI/TIA-568-C.2

Technical report	Manufacturer code	Certificate valid until
DELTA-N312636, DANAK-19J2119	1093BB	5 July 2011

This product has been tested by EC Cabling Group of DELTA and complies with the electrical requirements of the above specified standards and "Terms and conditions for use of the EC VERIFIED marking on generic cabling products", DQP231006. The testing included measurement of NEXT with a compliant test plug and calculation of all the 12 test cases in both measurement directions. The product takes part in a maintenance of certification schedule, which implies that DELTA EC Cabling performs a quality audit of the manufacturer's production and QA sites. The maintenance testing of the product is performed on a sample basis once a year.

Hørsholm, 5 July 2010

Erik Bech
Test Manager

Claude Videt
Project Manager

DELTA
Venlighedsvej 4
2970 Hørsholm
Denmark

Tel. +45 72 19 40 00
Fax +45 72 19 40 01
www.delta.dk/cable

TEST Reg. no. 19