



We help ideas meet the real world



Compliance Statement

No. 2010-185

Screened Channel, Class E_A for 10GBASE-T

Company

HellermannTyton Data Limited
Cornwell Business Park
Salthouse Rd
Brackmills, Northampton, NN4 7EX
United Kingdom

Channel Identification (3 connector model)

Horizontal cable:

HellermannTyton Deca¹⁰ F/FTP C_{6A} Cable

Flexible Patch Cords:

HellermannTyton Deca¹⁰ F/FTP C_{6A} Patch Cords

Telecommunications Outlet:

HellermannTyton Deca¹⁰ F/FTP C_{6A} Keystone Outlet

Patch Panel:

HellermannTyton Deca¹⁰ F/FTP C_{6A} Keystone Panel

Generic cabling standards, cabling components standard

- Amendment 1 to ISO/IEC 11801:2008
- EN 50173:2007
- ISO/IEC TR 24750
- ANSI/TIA/EIA-568C.2 Category 6A
- ANSI/TIA/EIA TSB-155

Technical report

DELTA-N312802, DANAK-19J2284

Manufacturer code

1900A

Certificate valid until

5 August 2011

This product has been tested by DELTA EC Cabling Group and complies with the electrical requirements of the above specified standards and "Terms and conditions for use of the EC VERIFIED marking on generic cabling products", DQP231006. The product takes part in a maintenance of certification schedule, which implies that DELTA EC Cabling performs a sample test of the product once a year.

Hørsholm, 5 August 2010

Erik Bech
Test Manager

Claude Videt
Project Manager

DELTA

Venlighedsvej 4
2970 Hørsholm
Denmark

Tel. +45 72 19 40 00
Fax +45 72 19 40 01
www.delta.dk/cable

